

Hutchinson County is repairing roof on the Hutchinson County Courthouse and the Hutchinson County Jail in Stinnett, TX. The specifications are below. Bids need to be received in the Hutchinson County Auditor's office, P O Box 850, Stinnett, TX 79083, by 12:00PM, August 31st, 2017. Questions can be directed to 806-878-4015. Bids will be opened in Commissioners Court September 11th, 2017.

#### Polyurethane Foam Repair for less than ½ in deep hail hits

1. Power wash entire roof coatings (3500psi or greater)
2. After roof has dried install fastener grade caulk in deep penetrations caused by storm
3. Install primer coating on roof
4. Install elastomeric coating and back roll with roller to work coating into torn coatings
5. After coating dries install final layer of elastomeric rubberized coating

Coating should be applied with airless sprayer @ 2200 psi for good coverage

Coating to be applied @ 2 gallon per sq per layer (4 gallon per sq total)

Primer will be applied @ 1.5 gallon per sq

Minimum Coating Properties required:

1. 85% reflectivity
2. 250% elongation
3. 14% permeability
4. 95psi tear resistance
5. 300psi tensile strength